EMORY UNIVERSITY | Environmental Health and Safety Office
Research Administration

1762 Clifton Road, Suite 1200
Atlanta, Georgia 30322
(404) 727-5922
FAX: (404) 727-9778

EMORY UNIVERSITY HOSPITAL MIDTOWN
UNDERGROUND STORAGE TANK
CATHODIC PROTECTION RECTIFIER LOG

Instructions:

- Use this form for the EUHM UST Cathodic Protection Rectifier.
- Complete and document the inspection of the rectifier every 30 days.
- Keep this form in the Underground Storage Tank (UST) documentation binder for 3 years.
- If the rectifier reading is outside of the targeted ranges for the facility (listed below), contact EHSO at 404-727-5922 and the company that maintains the cathodic protection system.

Target Voltage Reading: 6 – 10 volts **Target Amp Reading:** 1 – 2 amperes

Date	Name	DC Output		Comments
		Voltage Reading	Amp Reading	